



- NOTES:
1. CONCRETE TO HAVE STRENGTH OF 3000 P.S.I. IN 28 DAYS 2" TO 4" SLUMP.
 2. STEEL TIES-9" #4 BAR 24" O.C.
 3. PANELS TO BE 5 FEET LONG
 4. EXPANSION JOINTS TO BE PLACED AT SIDES OF DRIVEWAY APPROACHES, UTILITY VAULTS & AT SPACING NOT TO EXCEED 90' OR AS DIRECTED BY THE ENGINEER.
 5. DRAIN BLOCKOUTS IN CURBS SHALL BE EXTENDED TO BACK OF SIDEWALK WITH 3" DIA. SCH. 40 ABS OR PVC PIPE AT 2% SLOPE, CONTRACTION JOINT TO BE PLACED OVER PIPE.
 6. BROOM TRANSVERSE TO DIRECTION OF PEDESTRIAN TRAVEL (TYP.)

LEGEND:
 ↓ CROSS SLOPE 1.5% MAX (MAX 2.0 % FINISHED SURFACE SLOPE)

	CURBLINE SIDEWALK 6' DOWELED INTO EXISTING CURB	ENGINEERING DEPARTMENT 1924 COUNCIL STREET P.O. BOX 326 FOREST GROVE, OR 97116	DRAWING NO. 103
		LAST REV. 7/20/22	