



**NOTE:**

1. ALL PIPE TO CONFORM TO AWWA C151 CLASS 52.
2. ALL FITTINGS AND JOINTS TO BE MECHANICALLY RESTRAINED.
3. TO MINIMIZE WATER SHUT OFF TIME, PRE-FABRICATE ADJUSTMENT SECTION PRIOR TO WATER SHUT OFF.
4. DISINFECT ADJUSTMENT SECTIONS PRIOR TO CONNECTION TO EXISTING WATER MAIN.
5. THIS DETAIL NOT TO BE USED FOR SANITARY SEWER CROSSINGS.