



12" DIAMETER X 3" DEEP SUMP.  
 FOR SUMP LOCATION SEE WMV-3B AND  
 WMV-3C.  
 ADJUST PIPING AND PIPE STRAP  
 LOCATIONS AS REQUIRED.

**NOTES:**

1. SUMP PUMP – EBARA EPD-3AS1, HONDA WSP33K1AA, OR APPROVED EQUAL
2. MOUNT GFI RECEPTACLE 6" BELOW CEILING OF VAULT UNLESS LOCATED OTHERWISE BY NATIONAL AND/OR LOCAL ELECTRIC CODES. (GFI RECEPTACLE NOT SHOWN).
3. GFI RECEPTACLE SHALL BE LOCATED SO THE SUMP PUMP ELECTRICAL CORD WILL PLUG DIRECTLY INTO IT.

	<h2>SUMP PUMP INSTALLATION</h2>	<b>ENGINEERING DEPARTMENT</b> 1924 COUNCIL STREET P.O. BOX 326 FOREST GROVE, OR 97116	<b>DRAWING NO.</b> 416
		LAST REV. 9/21/23	