



NOTES:

1. FOR 12" AND SMALLER WATER MAINS
2. VENT PIPING TO BE GALV.
3. SLOPE COPPER TUBING FROM MAIN UP TO AIR VALVE 1% MIN.
4. ENCASE TUBING FROM WATER MAIN TO BOX WITH 6 INCHES OF SAND